

CERTIFICATE OF COMPLIANCE

Certificate Number E161256
Report Reference E161256-19990429
Issue Date 2020-APRIL-09

Issued to: CMP PRODUCTS
GLASSHOUSE ST
ST PETERS
NEWCASTLE-UPON-TYNE
NE6 1BS UNITED KINGDOM

**This certificate confirms that
representative samples of**

CABLE SEALING FITTINGS FOR USE IN HAZARDOUS
LOCATIONS

Refer addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 2225, 4th Ed., Rev. 2019-05-23, Cables
and Cable-Fittings for Use in Hazardous (Classified)
Locations

Standard No. CSA C22.2 No. 174-18, 3rd Ed., Issued 2018-
01, Cables and cable glands for use in hazardous locations


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE


Certificate Number E161256
Report Reference E161256-19990429
Issue Date 2020-APRIL-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL Series PXSS2K, cable sealing fittings for use only with TC-ER-HL cable. For vertical or horizontal mounting in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups F and G hazardous locations. For use only with manufacturer's "Type 2122" sealing compound or "RapidEx" compound.

USL, CNL Series PXSS2K, Type TC (Tray Cable) cable sealing fittings for use only with tray cable. For vertical or horizontal mounting in Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G hazardous locations. For use only with manufacturer's "Type 2122" sealing compound or "RapidEx" compound.

Connector Cat. No.	Hub Trade Size	Diameter of Outer Sheath, mm (in.)
20SPXSS2K	M20 1/2 in. NPT	6.2 (0.24) - 12.0 (0.47)
20PXSS2K	M20 1/2 in. NPT	6.5 (0.26) - 13.5 (0.53)
20LPXSS2K	M20 1/2 in. NPT	10.0 (0.39) - 15.9 (0.63)
25PXSS2K	M25 3/4 in. NPT	11.1 (0.44) - 19.9 (0.78)
32PXSS2K	M32 1 in. NPT	17.0 (0.67) - 26.2 (1.03)
32LPXSS2K	M32 1 in. NPT	20.0 (0.79) - 27.4 (1.079)
40PXSS2K	M40 1-1/4 in. NPT	22.0 (0.87) - 32.1 (1.26)
50SPXSS2K	M50 1-1/2 in. NPT	29.5 (1.16) - 38.1 (1.5)
50PXSS2K	M50 2 in. NPT	35.6 (1.4) - 44.0 (1.73)
63SPXSS2K	M63 2 in. NPT	40.1 (1.58) - 49.9 (1.96)
63PXSS2K	M63 2-1/2 in. NPT	47.2 (1.86) - 55.9 (2.20)
75SPXSS2K	M75 2-1/2 in. NPT	52.8 (2.08) - 61.9 (2.44)
75PXSS2K	M75 3 in. NPT	59.1 (2.33) - 67.9 (2.67)
90PXSS2K	M90 3 in. NPT	66.6 (2.62) - 79.3 (3.12)



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

