

Certificate of Compliance

Certificate Number:

UL-US-L161256-08311-
92110002-1

Report Reference:

E161256-20001129

Issue Date:

2024-01-11

Issued to:

**CMP Products Ltd
Glasshouse St
St Peters Newcastle-Upon-Tyne NE6 1BS
United Kingdom**

This certificate confirms that representative samples of:

CYMX - Cable Sealing Fittings for Use in Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 2225, Edition 4, Issued 2013-09-30, Revised 2020-02-06

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-L161256-08311-92110002-1
Report reference E161256-20001129
Date 2024-01-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Metal Clad (MC) cable sealing fittings for use in:
Class I, Division 2, Groups A, B, C and D,
Class II, Division 2, Groups F and G, and
Class III Hazardous Locations.

Model	Product Description
TMCX, with optional CMP prefix, followed by 05S, 050, 075, 20S, 25S, 100, 125, 150, 200, 250, 300, 350, 400, may be followed by A, NB or SS, may be followed by alphanumeric characters. For vertical or horizontal mounting. For use only with manufacturer's "Cedesa" Type 2122 sealing compound. Conduit entry sizes 1/2 in. to 4 in. and M20 to M115 inclusive. When used with cable employing an interlocking steel, aluminum or continuous corrugated aluminum armor.	Cable Sealing Fittings

Metal Clad (MC) cable sealing fittings for use in:
Class I, Groups A, B, C and D,
Class II, Groups E, F and G, and
Class III Hazardous Locations.

Model	Product Description
TMCX, with optional CMP prefix, followed by 05S, 050, 075, 20S, 25S, 100, 125, 150, 200, 250, 300, 350 or 400, may be followed by A, NB or SS, may be followed by alphanumeric characters. For vertical or horizontal mounting. For use only with manufacturer's "Cedesa" Type 2122 sealing compound. Conduit entry sizes 1/2in. to 4 in. and M20 to M115 inclusive. When used with Type MC-HL cable employing continuous corrugated aluminum armor.	Cable Sealing Fittings



David Picuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

