

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E161256  
**Report Reference** E161256-20200729  
**Issue Date** 2020-August-04

**Issued to:** CMP Products Ltd  
Glasshouse St  
St Peters  
Newcastle-Upon-Tyne  
NE6 1BS UNITED KINGDOM

**This certificate confirms that  
representative samples of**

CABLE SEALING FITTINGS FOR USE IN HAZARDOUS  
LOCATIONS  
See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL2225, Cables and Cable-Fittings For Use In Hazardous  
(Classified) Locations  
UL514B, CONDUIT, TUBING, AND CABLE FITTINGS  
CSA C22.2 No. 174-18, Cables and cable glands for use in  
hazardous locations  
CSA C22.2 No. 18.3-12 Conduit, Tubing, and Cable Fittings

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E161256  
**Report Reference** E161256-20200729  
**Issue Date** 2020-August-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - Series TMC2X, integrally sealed (SL) metal-clad cable connectors for use in Class I Division 1 Groups, A, B, C, D; Class II Division 1 Groups E, F, G; Class III; Hazardous Areas when used with corrugated MC-HL (metal-clad) with aluminum or galvanized steel armour. Series Cat No TMC2X, followed by -050, followed by A, B, NB or SS, followed by 075 or 099; Series Cat No -075, followed by A, B, NB or SS, followed by 075, 099 or 118; Series Cat No -100, followed by A, B, NB or SS, followed by 118 or 137; Series Cat No -125, followed by A, B, NB or SS, followed by 137 or 162; for use with manufacturer's Type EP2122 or RapidEx sealing compound.

CNL - Series TMC2X, integrally sealed (SL) metal-clad cable connectors for use in Class I Division 1 Groups, A, B, C, D; Class II Division 1 Groups E, F, G; Class III; Hazardous Areas when used with jacketed interlocked TECK type cables or corrugated MC-HL (metal-clad) with aluminum or galvanized steel armour. Series Cat No TMC2X, followed by -050, followed by A, B, NB or SS, followed by 075 or 099; Series Cat No -075, followed by A, B, NB or SS, followed by 075, 099 or 118; Series Cat No -100, followed by A, B, NB or SS, followed by 118 or 137; Series Cat No -125, followed by A, B, NB or SS, followed by 137 or 162; for use with manufacturer's Type EP2122 or RapidEx sealing compound.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

