

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130624 – E201187  
**Report Reference** E201187 -19990430  
**Issue Date** 2013-June-24

**Issued to:** CMP PRODUCTS  
GLASSHOUSE ST  
ST PETERS  
NEWCASTLE-UPON-TYNE, NE6 1BS UNITED KINGDOM


**This is to certify that representative samples of** Marine Shipboard Cable Sealing Fittings for Use in Hazardous Locations  
Series PXSS2K.  
(See following page for additional model information.)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 2225, "Cables and Cable Fittings for Use in Hazardous (Classified) Locations" and CSA-C22.2 No. 174 (1984), "Cables and Cable Glands for Use in Hazardous Locations."

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130624 – E201187  
**Report Reference** E201187 -19990430  
**Issue Date** 2013-June-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Additional Model information:

Series PXSS2K, Marine shipboard cable sealing fittings for use only within armored cable. For vertical or horizontal mounting in hazardous locations. For use only with manufacturer's "Denso" Type 2122 sealing compound.

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G hazardous locations when provided with NPT or a minimum 10 full ISO metric threads.

Class I, Division 2, Groups C and D; Class II, Division 2, Groups F and G hazardous locations when provided with a minimum of 5 full ISO metric threads.

Connector Cat. No.	Hub Trade Size	Diameter of Outer Sheath, mm (in.)
20s PXSS2K	M20 1/2 in. NPT	6.2 (0.24) - 12.0 (0.47)
20PXSS2K	M20 1/2 in. NPT	6.5 (0.26) - 13.5 (0.53)
20LPXSS2K	M20 1/2 in. NPT	10.0 (0.39) - 15.9 (0.63)
25PXSS2K	M25 3/4 in. NPT	11.1 (0.44) - 19.9 (0.78)
32PXSS2K	M32 1 in. NPT	17.0 (0.67) - 26.2 (1.03)
32LPXSS2K	M32 1 in. NPT	20.0 (0.79) - 27.4 (1.079)
40PXSS2K	M40 1-1/4 in. NPT	22.0 (0.87) - 32.1 (1.26)
50SPXSS2K	M50 1-1/2 in. NPT	29.5 (1.16) - 38.1 (1.5)
50PXSS2K	M50 2 in. NPT	35.6 (1.4) - 44.0 (1.73)
63SPXSS2K	M63 2 in. NPT	40.1 (1.58) - 49.9 (1.96)
63PXSS2K	M63 2-1/2 in. NPT	47.2 (1.86) - 55.9 (2.20)
75SPXSS2K	M75 2-1/2 in. NPT	52.8 (2.08) - 61.9 (2.44)
75PXSS2K	M75 3 in. NPT	59.1 (2.33) - 67.9 (2.67)
90PXSS2K	M90 3 in. NPT	66.6 (2.62) - 79.3 (3.12)



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

