

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170602-E161256  
**Report Reference** E161256-20001129  
**Issue Date** 2017-JUNE-02

**Issued to:** CMP Products Ltd  
Glasshouse St  
St Peters  
Newcastle-Upon-Tyne  
NE6 1BS UNITED KINGDOM

**This is to certify that  
representative samples of**

CABLE SEALING FITTINGS FOR USE IN HAZARDOUS  
LOCATIONS

Refer to addendum page for Models/Product.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 2225 Standard for Cables and Cable-Fittings for Use in  
Hazardous (Classified) Locations.

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE


**Certificate Number** 20170602-E161256  
**Report Reference** E161256-20001129  
**Issue Date** 2017-JUNE-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Models/Product

MC cable sealing fittings, Series TMCX with optional CMP prefix, followed by 05S, 050, 075, 20S, 25S, 100, 125, 150, 200, 250, 300, 350, 400, may be followed by A, NB or SS, for use only with cable employing an interlocking steel, aluminum or continuous corrugated aluminum armor. For vertical or horizontal mounting. For use only with manufacturer's "Denso" Type 2122 sealing compound. For use in Class I, Division 2, Groups A, B, C and D, Class II, Division 2, Groups F and G, and Class III Hazardous Locations. Conduit entry sizes ½ in. to 4 in. and M20 to M115 inclusive.

MC cable sealing fittings, Series TMCX with optional CMP prefix, followed by 05S, 050, 075, 20S, 25S, 100, 125, 150, 200, 250, 300, 350 or 400, may be followed by A, NB or SS, for use with Type MC-HL cable employing continuous corrugated aluminum armor. For vertical or horizontal mounting. For use only with manufacturer's "Denso" Type 2122 sealing compound. For use in Class I, Groups A, B, C and D, Class II, Groups E, F and G, and Class III Hazardous Locations. Conduit entry sizes ½ in. to 4 in. and M20 to M115 inclusive.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

